

Issue Date: 10-01-2013
Revision Date: 05-31-2019
Renewal Date: 01-01-2020

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION
Section: 07 30 05 – Roofing Felt and Underlayment

REPORT HOLDER:
Epilay Inc.
21175 S. Main Street, E1 Unit C
Carson, California 90745
<http://www.epilay.com>

ADDITIONAL LISTEE:
Building Products of Canada Corporation
9500 St. Patrick Street
Lasalle, Quebec H8R 1R9

REPORT SUBJECT:
Epilay PlasFelt, Superior, Ultra, and Platinum Roofing Underlayments

ADDITIONAL LISTEE SUBJECT:
SUREDECK Roofing Underlayment

1.0 SCOPE OF EVALUATION

This Research Report addresses compliance with the following Codes:

- 2018, 2015, and 2012 *International Building Code*® (IBC)
- 2018, 2015, and 2012 *International Residential Code*® (IRC)

2.0 USES

Epilay PlasFelt, Superior, Ultra, and Platinum roofing underlayments are used in the field of the roof as an alternative to the ASTM D226, Type I and Type II, roof underlayments specified in Chapter 15 of the IBC and Chapter 9 of the IRC.

The underlayments may be used in areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier roof underlayment, when installed as noted in Section 4.2.

The underlayments may be used as components of classified assemblies when installed as described in this report.

The underlayments have been evaluated for the properties as listed in Table 1.

3.0 DESCRIPTION

Epilay PlasFelt, Superior, Ultra, and Platinum are four-layered roofing underlayments consisting of a non-woven polypropylene scrim bonded to a woven polypropylene scrim and coated on both sides. The nominal weights of the Epilay Superior, Ultra, and Platinum underlayments are 2.0, 2.25, 2.90 and 3.70 pounds per 100 square feet respectively. Standard size rolls are 4 feet wide by 250 feet long.

Epilay Superior underlayment is also labeled for Building Products of Canada Corporation as SUREDECK underlayment.

4.0 INSTALLATION

4.1 General:

Installation of the underlayments must comply with the applicable Code, this report, and the report holder's published installation instructions.

The underlayments must be installed in accordance with the subsections of IBC Section 1507 and IRC Section R905 applicable to the roof covering being installed. The underlayments must be laid with the print side up, with laps as required by the applicable Code, evaluation report, or manufacturer's instructions, whichever is more restrictive.

The roof covering may be installed immediately following the underlayment application and the underlayment must be covered within the time designated in the report holder's published installation instructions.

4.2 Ice Barrier:

In areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier, two layers of the underlayments solidly cemented together with a low solvent based roofing cement, complying with ASTM D4586 Type 1,



may be used provided the ice barrier extends up the roof a minimum distance of 24 inches inside the interior wall line of the building. The underlayments installed in the field of the roof must overlap the ice barrier.

4.3 Fire Classification:

The roof underlayments may be used as a component of a classified roof assembly when specifically recognized as such in a listing approved by the Code official. The underlayments may also be used as an alternative to the underlayments specified in the Code for roof coverings permitted under the Exceptions to IBC Section 1505.2 and IRC Section R902.1, and may be used where non-classified roofing is permitted in IBC Section 1505.5. Except in buildings permitted to have non-classified roofing, the roof deck must be wood structural panels having a minimum thickness described in Table 2 of this report.

In addition, when installed in accordance with the assemblies described in Table 2 of this report, Epilay PlasFelt, Superior, Ultra, and Platinum roofing underlayments meet Class A fire classification.

5.0 CONDITIONS OF USE

The underlayments described in this report comply with, or are suitable alternatives to, what is specified in those Codes listed in Section 1.0 of this report, subject to the following conditions:

5.1 Installation must comply with this report, the applicable Code, and the report holder's published installation instructions. In the event of a conflict between the manufacturer's instructions and this report, this report governs.

5.2 Installation is limited to use with approved mechanically attached roof covering systems.

5.3 Installation is limited to installations where the roof covering does not involve hot asphalt or coal-tar pitch.

5.4 Installation is limited to roof slopes of 2:12 (17%) or greater.

5.5 Attic ventilation must be provided in accordance with the applicable Code since there are no requirements to

evaluate vapor permeability of the underlayment.

5.6 Installation for fire classification is limited to wood structural panels having a minimum thickness described in Table 2 of this report.

5.7 PlasFelt, Superior, Ultra, Platinum, and SUREDECK roofing underlayments are manufactured under a quality control program with inspections by Intertek Testing Services NA Inc.

6.0 SUPPORTING EVIDENCE

6.1 Reports of tests in accordance with ASTM E108 (UL 790).

6.2 Data in accordance with the ICC-ES Acceptance Criteria for Roof Underlayments (AC188), dated February 2012 (editorially revised December 2015).

6.3 Intertek Listing Report "[Epilay Superior, Ultra, and Platinum Roofing Underlayments](#)".

6.4 Intertek Listing Report "[Building Products of Canada - SUREDECK Underlayment](#)".

7.0 IDENTIFICATION

The roof underlayments are marked at 24 inch intervals with the product name (PlasFelt, Superior, Ultra, Platinum or SUREDECK). Each roll of the product is labeled with the report holder's name, the product name, the manufacturing date code, and the Code Compliance Research Report number (CCRR-1004).

8.0 OTHER CODES

This section is not applicable.

9.0 CODE COMPLIANCE RESEARCH REPORT USE

9.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

9.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.





9.3 Reference to the <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



545 E. Algonquin Road • Arlington Heights • Illinois • 60005
intertek.com/building





TABLE 1 – PROPERTIES EVALUATED

PROPERTY	IBC SECTION ¹	IRC SECTION ¹
Physical Properties	104.11, 1506, and 1507	R104.11, R904, and R905
Fire Classification	1505	R902.1
Ice Barrier	1507	R905

¹Referenced sections apply to 2018 IBC and IRC

TABLE 2 – FIRE CLASSIFICATION

CLASSIFICATION AND SLOPE	DECK	UNDERLAYMENT	ROOF COVERING
Class A 2:12 or greater	Minimum nominal 15/32 inch thick Code-compliant exterior grade plywood	One layer of Epilay PlasFelt, Superior, Ultra, or Platinum roofing underlayment	Asphalt shingles Listed per ASTM D3462 with a minimum weight of 190 pounds per 100 square feet
Class A 2:12 or greater	Minimum nominal 5/8 inch thick Code-compliant exterior grade plywood	One layer of Epilay Superior, Ultra, or Platinum roofing underlayment	Concrete roof tile meeting Class A fire classification with a minimum weight of 10.3 pounds per square feet ¹

¹Concrete tile must comply with IBC Section 1507.3 or IRC Section 905.3, as applicable.